

For more visit estesvalleyfire of profits equivalent of dynamics.

WHAT TO KNOW

MORE INFO



For more information visit us at: estesvalleyfire.org/prevention

Did You Know

A 20-gallon tank of propane is equivalent to 170 sticks of dynamite



Estes Valley Fire Protection District

prevention@estesvalleyfire.org

Protecting the Estes Valley since 1907

A Fire Safety Business Resource

Mobile Food Vehicles & Food Vendors

Fire & Life-Safety Checklist

Below are important fire & life-safety requirements from the adopted Fire Code that apply to mobile food vehicles

<u>Fire Protection Systems</u>	
	A Type I hood with a fire suppression system is provided for cooking. Suppression nozzle coverage is correct for cooking appliances. Hoods are serviced by a technician every 6 months at minimum. All gas stoves, grills & burners are UL Listed or AGA approved. Cooking appliances are cleaned regularly without grease buildup. Hoods, shafts & fan are cleaned every 6 months at minimum. Manual pull station is accessible and unobstructed.
Means of Egress (Exiting)	
	All required exit doors can be opened from the interior freely.
<u>Extinguishers</u>	
	Class-K portable fire extinguisher(s) are provided. 2-A:10-B:C dy chemical-type is provided. All are mounted, accessible, and serviced annually by a technician.
Solid Fuel Cooking Appliances	
(Pi	zza Ovens, BBQ Smokers, or Similar)
	Chimneys are maintained clean with an approved spark arrestor. Approved ash disposal containers with a tight fitting lid are used.
<u>Electrical</u>	
	Extension cords or multi-plug adapters are not used. Electrical service panels are labeled, accessible, and unobstructed. Generators are safely located and free from vehicle impact. Generator electrical cords are maintained without damage.
Compressed Gases (LP-Gas, CNG, etc.)	
	Shut-off valves are present and accessible.

- ☐ LP-Gas (Propane)- a Listed LP-gas alarm is provided.
- ☐ CNG (Natural gas)- a Listed methane gas alarm is provided.
- ☐ Containers are labeled with the name of the gas & correct color label.

Location

- ☐ 10-feet clearance is maintained to buildings, exits, tents, combustible structures & vegetation, and other food trucks.
- ☐ 15-feet clearance is provided to any fire hydrant.